

# ELECTRICAL SAFETY RECALL

## Single module Compact RCBO Noark model no. Ex9NLE-N

### Identification:

Products affected include:

- 90552 - 1 module RCBO 10A 30mA
- 90553 - 1 module RCBO 16A 30mA
- 90554 - 1 module RCBO 20A 30mA
- 90555 - 1 module RCBO 25A 30mA
- 90556 - 1 module RCBO 32A 30mA
- 90703 - 1 module RCBO 40A 30mA

These products have been sold throughout Victoria, South Australia and Western Australia between March 2016 and October 2019.

**Defect:** The product does not comply with the Australian Standard.

**Hazard:** Risk of electrical shock.

### Action required:

Electrical wholesalers are required to stop selling these products. Electrical contractors are required to stop installing the above products and contact DKSH Australia Pty Ltd to arrange return of their stock and/or replacement of the installed products.

### For further information

Please direct all calls and any queries concerning this recall to DKSH by phoning **1800 006 137** (during business hours), emailing [recall.au@dksh.com](mailto:recall.au@dksh.com) or by visiting <https://dksh.com/noark-rcbo-recall>



See [www.recalls.gov.au](http://www.recalls.gov.au) for Australia Product Recalls Information